

Draft Minnesota Rules, chapter 4725

SUBMERGED CLOSED LOOP HEAT EXCHANGERS

This is a DRAFT document. None of the proposed language changes are adopted or reflect current rule. Proposed language revisions are marked from the previously posted rule draft document. Language additions are underlined. Existing language proposed for removal is stricken with a ~~strike-out~~. Formatting changes are accepted between document versions.

1 **4725.0100 DEFINITIONS.**

2 Subpart. 47b. **Submerged closed loop heat exchanger.** “submerged closed loop heat
3 exchanger” has the meaning given in Minnesota Statutes, section 1031.005, subdivision 17a.

4 Subp. 47c. **Submerged closed loop heat exchanger system.** “Submerged closed loop heat
5 exchanger system” means ~~one or more wells containing a~~ submerged closed loop heat
6 exchangers installed in one or more water-supply wells connected to within a single
7 building HVAC system for the use of heating or cooling.

Minnesota Department of Health
Well Management Section
625 Robert St. N.
PO Box 64975
St. Paul, MN 55164-0975
651-201-4600 or 800-393-9808
wellrules.mdh@state.mn.us
www.health.state.mn.us

05/06/2024

To obtain this information in a different format, call: 651-201-4600 or 800-393-9808.